
# MECHANICAL CONNECTORS



# **MF4 Hybrid Connectors**

- Heat Shrink Section



## **Principle Application:**

Stranded and solid shaped service conductors.

### Range:

		Core C.S.A. (mm <sup>2</sup> )		
Product Reference	Туре	Min	Max	
MF4/24	Straight Through	6*	16	
MF4/25	Moisture Blocked	6*	16	

Note: For jointing other core configurations/sizes please contact Sicame Technical Dept

The **Hepworth MF4** hybrid range of mechanical connectors are designed for straight connections on stranded or solid service cables. The aluminium connector yoke is electro-tinned as standard and is supplied with brass grub screws making it suitable for jointing copper/aluminium, sector/circular shaped conductors.

This particular range of mechanical ferrules have been specifically designed for joints where a cold or heat shrink sleeving is a requirement.



# MECHANICAL CONNECTORS

# **MF4 Hybrid Connectors**

- Heat Shrink Section

## **Secondary Application:**

Stranded and solid circular conductors.

### Range:

Product	Type	Maximum Core C.S.A. (mm²)	
Reference		Solid	Stranded
MF4/24	Straight Through	35	35
MF4/25	Moisture Blocked	35	35

<sup>\*</sup> Note: Conductors below 6mm² should be doubled and, if necessary, doubled again to achieve a satisfactory cross sectional area.

# Physical Dimensions: 'D' A/F

'A'

Product Reference	Dimensions (mm)			
	'A'	'B'	,C,	'D'
MF4/24	35.0	19.0	11.7	3.0
MF4/25	44.0	19.0	11.7	3.0

### **Material:**

**Body:** Aluminium Alloy (Tinned)

Screws: Brass

### **Test Specification:**

**BS EN 61238-1 : 2003** Compression and Mechanical Connectors for power cables for rated voltages up to 36 kV. Test Methods and Requirements. Test report numbers—TTR/320, TTR/321, TTR/324, TTR/325, TTR/331, TTR/333

### **Fitting Instructions:**

- 1. Strip the core insulation equal to the length of the connector + 3mm.
- 2. Thoroughly abrade and clean all conductors to be jointed.
- 3. Align cores within connector and tighten screws on each side of the connector consecutively, until tight.

**Note:** \* Conductor cores 4mm² and below should be doubled, and if necessary doubled again, to achieve the necessary cross-sectional area.

