

FXCTV 3x500mm²
 FXCTV 3x240mm²
 FXCTV 3x95mm²

- see cable
 95, 240, 500

ABB

Tender Elsam
 Our ref 05-1059
 Page 4 of 14
 Rev. 050929-4
 2005-09-29

(A3)

Burbo Offshore Windfarm
ABB Power Technologies AB High Voltage Cables

4.7. Fiber optic cable

The fiber optic cable is the same type (copper tube and PE sheath) as we have used in the wind farms at "Utgrunden", "Yttre Stengrund", "Samsø", "Nysted", and other projects.
 The fiber optic cable is of ribbon type.


Typical fiber optic cable design & properties

CABLE PROPERTIES

Bending radius, permanently and during installation minimum	0,75 m
Crush resistance	100 kN/m
Impact resistance	50 J
Tensile strength,	1 kN
Cable net weight	0,4 kg/m
Factory length, without splice	24 km

CONSTRUCTION

	Diameter
1 Acrylate coated ribbon	1.1x0.4 mm
2 Slotted core: Polyethylene	8.5 mm
3 Filling compound: Thixotropic gel	
4 Strength member: Fibre Reinforced Plastic	3.5 mm
5 Wrapping: Polyester tape	
6 Sheath: Polyethylene, black	13 mm
7 Copper sheath	14 mm
8 Sheath: Polyethylene, black	18 mm



Burbo Offshore Windfarm
ABB Power Technologies AB High Voltage Cables

4.7.1. Typical geometrical and mechanical data for the fibres

Maximum strength of fibre	50 ² N	N
Proof test tension	8,6 N	N
Proof test extention	1 %	%
Proof test time	1 s	s
Extention at maximum cable tention	<0,3 %	%
Impact at maximum cable tention	<216 N/mm ²	N/mm ²
Continuous extention after maximum cable tention	<0,05%	%
Continuous impact after maximum cable tention	< 36 N/mm ²	N/mm ²
Fibre lifetime at continuous impact/extention as indicated above	> 40 year	year
Maximum supply length	25 000 m	m

1; 60 mm and 100 turns gives a maximum of 0.05 dB at 1550 nm.

2; Typical value for testing 0.5 m lengths.

Optical data for the fibres:

Attenuation in fibres at 1310 nm (mean value)	< 0.35 dB/km	dB/km
Attenuation in fibres at 1310 nm (maximum value)	< 0.39 dB/km	dB/km
Attenuation in fibres at 1550 nm (mean value)	< 0.200 dB/km	dB/km
Attenuation in fibres at 1550 nm (maximum value)	< 0.210 dB/km	dB/km
Total dispersion at 1310 nm	< 2,8 ps/km x nm	ps/km x nm
Total dispersion at 1550 nm	< 18 ps/km x nm	ps/km x nm
Cut-off wave length after cabling	< 1260nm	nm

4.8. Cable core binder

A woven polymeric tape will keep the three cable-cores, polymeric profiles and fiber optic cable together.

4.9. Bedding

Bitumen impregnated tape.

4.10. Armour

Galvanized steel wires covered by a layer of bitumen (Ø 4mm) will protect the cable during laying and against anchors, fishing-gear etc.

4.11. Outer serving

The outer protective cover consist of bitumen and two layers of polypropylene yarn, where the outer layer will be black with different numbers of orange lines in order to simplify identification between the different cross sections.



Burbo Offshore Windfarm
ABB Power Technologies AB High Voltage Cables

4. MECHANICAL DATA FOR FXCTV 3x500MM² CABLE

Bending radius complete cable:			
at installation:	2,0	m	
at laying with tension:	2,5	m	
when installed:	1,4	m	
Bending radius each phase):			
at installation:	0,9	m	
when installed:	0,6	m	
Coil:			
circular: (diameter)	(alt.1)	8,0	m
oval : (size)	(alt.2)	5 x 14	m
	(alt.3)	6 x 12	m
	(alt.4)	7 x 10	m
min. drop height alt.1		8,0	m
min. drop height alt.2		10,0	m
min. drop height alt.3		10,0	m
min. drop height alt.4		9,0	m
Maximum tension at laying:	160	kN	
< 100 m from conductor joint:	110	kN	

5. MECHANICAL DATA FOR FXCTV 3x240MM² CABLE

Bending radius complete cable:			
at installation:	2,1	m	
at laying with tension:	2,5	m	
when installed:	1,2	m	
Bending radius each phase:			
at installation:	0,8	m	
when installed:	0,6	m	
Maximum tension at laying	75	kN	

FXCTV 3x500mm²
FXCTV 3x240mm²
FXCTV 3x95mm²



Tender Elsam
Our ref 05-1059
Page 7 of 14
Rev. 050929-4
2005-09-29

Burbo Offshore Windfarm
ABB Power Technologies AB High Voltage Cables

6. MECHANICAL DATA FOR FXCTV 3x95MM² CABLE

Bending radius complete cable:		
at installation:	2,1	m
at laying with tension:	2,5	m
when installed:	1,1	m
Bending radius each phase:		
at installation:	0,7	m
when installed:	0,5	m
Maximum tension at laying:	31	kN

7. TESTING OF FXCTV CABLES

Each completed cable length including possible factory joints will be tested according to Inspection and Test Plan (ITP), please see appendix.

Burbo Offshore Windfarm
ABB Power Technologies AB High Voltage Cables

8. CALCULATED RESULTS FXCTV 3x500mm² (ACCORDING TO IEC 60287)

Calculated results, three core cables		
FXCTV 3x500mm ² 34kV		
2005-09-29		
a.c resistance at max. temperature, R_{ac}	0,0499 Ω /km	At I_{max}
Loss factor for sheath and screen:		
λ_1	0,0681	
λ_2	0,2688	
Thermal resistance of insulation, T_1	0,3405 K.m/W	
Thermal resistance of bedding, T_2	0,1336 K.m/W	
Thermal resistance of outer covering, T_3	0,0573 K.m/W	
Thermal resistance of surrounding, T_4	0,2378 K.m/W	
Max continuous conductor current, I_{max}	640,5 A	37,7 MVA at 34 kV
Non-adiabatic short circuit current, I	101,9 kA/0,5 sec.	Conductor
Non-adiabatic short circuit current, I	4,0 kA/0,5 sec.	Copper screen (per phase)
Conductor losses per phase	20,49 W/m	At I_{max}
Screen losses per phase	1,39 W/m	At I_{max}
Armour losses per phase	5,51 W/m	At I_{max}
Dielectric losses per phase, W_d	0,007 W/m	At 34 kV
Total losses per phase	27,40 W/m	
Capacitance, per phase	0,309 μ F/km	
Capacitive charging current, per phase	1,906 A/km	At 34 kV
Inductance between conductors, per phase	0,334 mH/km	
Inductive reactance, (star reactance)	0,105 Ω /km	
Electric stress at conductor screen	3,28 kV/mm	At 36 kV
Electric stress at insulation screen	2,09 kV/mm	At 36 kV
Positive sequence impedance per phase, Z_+	0,0668 0,1050	(1+j) Ω /km
Negative sequence impedance per phase, Z_-	0,0668 0,1050	(1+j) Ω /km

* Max continuous conductor current, I_{max} is based on 50°C air temperature.

Burbo Offshore Windfarm
ABB Power Technologies AB High Voltage Cables

9. CALCULATED RESULTS FXCTV 3x240mm² (ACCORDING TO IEC 60287)

Calculated results, three core cables		
FXCTV 3x 240mm ² 34kV		
2005-09-29		
a.c resistance at max. temperature, R_{ac}	0,0975 Ω /km	At I_{max}
Loss factor for sheath and screen:		
λ_1	0,0341	
λ_2	0,1331	
Thermal resistance of insulation, T_1	0,4476 K.m/W	
Thermal resistance of bedding, T_2	0,1405 K.m/W	
Thermal resistance of outer covering, T_3	0,0545 K.m/W	
Thermal resistance of surrounding, T_4	0,2702 K.m/W	
Max continuous conductor current, I_{max}	* 450,6 A	26,5 MVA at 34 kV
Non-adiabatic short circuit current, I	49,0 kA/0,5 sec.	Conductor
Non-adiabatic short circuit current, I	3,3 kA/0,5 sec.	Copper screen (per phase)
Conductor losses per phase	19,79 W/m	At I_{max}
Screen losses per phase	0,67 W/m	At I_{max}
Armour losses per phase	2,63 W/m	At I_{max}
Dielectric losses per phase, W_d	0,0052 W/m	At 34 kV
Total losses per phase	23,11 W/m	
Capacitance, per phase	0,217 μ F/km	
Capacitive charging current, per phase	1,336 A/km	At 34 kV
Inductance between conductors, per phase	0,386 mH/km	
Inductive reactance, (star reactance)	0,121 Ω /km	
Electric stress at conductor screen	3,54 kV/mm	At 36 kV
Electric stress at insulation screen	1,96 kV/mm	At 36 kV
Positive sequence impedance per phase, Z_+	0,1138 0,1212	(1+j) Ω /km
Negative sequence impedance per phase, Z_-	0,1138 0,1212	(1+j) Ω /km

* Max continuous conductor current, I_{max} is based on 50°C air temperature.

FXCTV 3x500mm²
FXCTV 3x240mm²
FXCTV 3x95mm²



Tender Elsam
Our ref 05-1059
Page 10 of 14
Rev. 050929-4
2005-09-29

Burbo Offshore Windfarm
ABB Power Technologies AB High Voltage Cables

10. CALCULATED RESULTS FXCTV 3x95mm² (ACCORDING TO IEC 60287)

Calculated results, three core cables FXCTV 3x95mm² 30 kV 2005-09-29

a.c resistance at max. temperature, R_{ac}	0,2465 Ω /km	At I_{max}
Loss factor for sheath and screen:		
λ_1	0,0124	
λ_2	0,0481	
Thermal resistance of insulation, T_1	0,6134 K.m/W	
Thermal resistance of bedding, T_2	0,1572 K.m/W	
Thermal resistance of outer covering, T_3	0,0625 K.m/W	
Thermal resistance of surrounding, T_4	0,3101 K.m/W	
Max continuous conductor current, I_{max}	* 267,0 A	15,7 MVA at 34 kV
Non-adiabatic short circuit current, I	19,5 kA/0,5 sec.	Conductor
Non-adiabatic short circuit current, I	2,8 kA/0,5 sec.	Copper screen (per phase)
Conductor losses per phase	17,57 W/m	At I_{max}
Screen losses per phase	0,22 W/m	At I_{max}
Armour losses per phase	0,84 W/m	At I_{max}
Dielectric losses per phase, W_d	0,0039 W/m	At 34 kV
Total losses per phase	18,64 W/m	
Capacitance, per phase	0,159 μ F/km	
Capacitive charging current, per phase	0,982 A/km	At 34 kV
Inductance between conductors, per phase	0,452 mH/km	
Inductive reactance, (star reactance)	0,142 Ω /km	
Electric stress at conductor screen	3,99 kV/mm	At 36 kV
Electric stress at insulation screen	1,79 kV/mm	At 36 kV
Positive sequence impedance per phase, Z_+	0,2615 0,1420	(1+j) Ω /km
Negative sequence impedance per phase, Z_-	0,2615 0,1420	(1+j) Ω /km

* Max continuous conductor current, I_{max} is based on 50°C air temperature.



Burbo Offshore Windfarm
ABB Power Technologies AB High Voltage Cables

11. CALCULATED LOSSES IN GRID LAYOUT:

The loss calculations are based on:

- Continuous load on each turbine. 3,6 MVA
- Number of turbines (Wtg) 25
- Seabed temperature at 3,0 m depth. 15 °C
- Thermal resistivity of seabed 0,7 K.m/W
- R at 30 MW (500mm²) 0,0524
- R at 30 MW (240mm²) 0,1084
- R at 30 MW (95mm²) 0,2479

A-1; B-2; C-3

From Wtg	To Wtg	Load MW	Current at 34 kV A	Cable size mm ²	Length Wtg - Wtg m	Vertical m	Loss / unit Load W/m	Dielectric W/m	Loss total Load kW	
Shore	A2	32,4	550,18	3 x 500	8470	8450	10 20	56,94	0,0210	483,40
A2	A3	28,8	489,05	3 x 500	600	560	80 40	44,99	0,0210	28,79
A3	A4	25,2	427,92	3 x 240	600	560	80 40	60,65	0,0210	38,81
A4	A5	21,6	366,79	3 x 240	600	560	80 40	44,56	0,0210	28,52
A5	A6	18	305,66	3 x 240	600	560	80 40	30,94	0,0156	19,80
A6	A7	14,4	244,52	3 x 95	600	560	80 40	43,68	0,0156	27,95
A7	A8	10,8	183,39	3 x 95	600	560	80 40	24,57	0,0156	15,72
A8	B8	7,2	122,26	3 x 95	790	750	80 40	10,92	0,0156	9,06
B8	B9	3,6	61,13	3 x 95	600	560	80 40	2,73	0,0156	1,75
Shore	B2	28,8	489,05	3 x 500	8480	8460	10 20	44,99	0,0210	382,40
B2	B3	25,2	427,92	3 x 240	600	560	80 40	60,65	0,0210	38,81
B3	B4	21,6	366,79	3 x 240	"	560	80 40	44,56	0,0210	28,52
B4	B5	18	305,66	3 x 240	"	560	80 40	30,94	0,0156	19,80
B5	B6	14,4	244,52	3 x 95	"	560	80 40	43,68	0,0156	27,95
B6	B7	10,8	183,39	3 x 95	"	560	80 40	24,57	0,0156	15,72
B7	C7	7,2	122,26	3 x 95	790	750	80 40	10,92	0,0156	9,06
C7	C8	3,6	61,13	3 x 95	600	560	80 40	2,73	0,0156	1,75
Shore	C1	28,8	489,05	3 x 500	8510	8490	10 20	44,99	0,0210	383,75
C1	C2	18	305,66	3 x 240	600	560	80 40	30,94	0,0156	19,80
C2	C3	14,4	244,52	3 x 95	"	560	80 40	43,68	0,0156	27,95
C3	C4	10,8	183,39	3 x 95	"	560	80 40	24,57	0,0156	15,72
C4	C5	7,2	122,26	3 x 95	"	560	80 40	10,92	0,0156	6,99
C5	C6	3,6	61,13	3 x 95	"	560	80 40	2,73	0,0156	1,75
C1	D1	7,2	122,26	3 x 95	790	750	80 40	10,92	0,0156	9,06
D1	D2	3,6	61,13	3 x 95	600	560	80 40	2,73	0,0156	1,75
1644,61										

1644,61

1,6 MW / 90 MW


FXCTV 3x500mm²
 FXCTV 3x240mm²
 FXCTV 3x95mm²



Tender Elsam
 Our ref 05-1059
 Page 12 of 14
 Rev. 050929-4
 2005-09-29

Burbo Offshore Windfarm
 ABB Power Technologies AB High Voltage Cables

12. CABLE DESIGN FXCTV 3x500MM²



Designation	FXCTV 3 x 500 mm ²		
Rated voltage	18/30 kV U _{max} 36kV		
Impulse level	170 kV		
Conductor			
type	round, compact		
material	copper		
longitudinal water seal	compound + swelling tape		
cross-section	3 x 500 mm ²		
diameter	26,2	mm	12,1
Conductor screen			
material	conductive PE		
thickness	1,0	mm	14,1
Insulation			
type	dry cured, triple extruded		
material	XLPE		
thickness	8	mm	22,1
Insulation screen			
material	conductive PE		
thickness	1,0	mm	23,1
Longitudinal water seal			
material	swelling tape		
thickness	0,6	mm	23,7
Metallic screen			
material	copper wires		
cross-section	3 x 17	mm ²	23,72
Longitudinal water seal			
material	swelling tape		
thickness	0,6	mm	24,3
Inner sheath			
material	conductive PE		
thickness	2,0	mm	26,3
Assembling			
material 1	polymeric profiles		
material 2	fibre optical cable		
material 3	grease		
Cable core binder			
material	polymeric tape		
thickness	0,2	mm	26,5
Bedding			
material	Bitumen impregnated tape		
thickness	0,5	mm	27,0
Armour			
material 1	Galvanized steel wires		
material 2	Bitumen		
wire diameter	4,0	mm	27,5
Armour			
material 1	Polypropylene yarns		
material 2	Bitumen		
thickness	4,0	mm	28,5
Complete cable			
diameter	≈ 140	mm	56,63
weight	≈ 35	kg / m	


FXCTV 3x500mm²
FXCTV 3x240mm²
FXCTV 3x95mm²



Tender Elsam
Our ref 05-1059
Page 13 of 14
Rev. 050929-4
2005-09-29

Burbo Offshore Windfarm
ABB Power Technologies AB High Voltage Cables

13. CABLE DESIGN FXCTV 3x240mm²



Designation	FXCTV 3 x 240 mm ²
Rated voltage	18/30 kV U _{max} 36kV
Impulse level	170 kV
Conductor	
type	round, solid (or compacted)
material	copper
cross-section	3 x 240 mm ²
Conductor screen	
material	conductive PE
thickness	1,0 mm
Insulation	
type	dry cured, triple extruded
material	XLPE
thickness	8 mm
Insulation screen	
material	conductive PE
thickness	1,0 mm
Longitudinal water seal	
material	swelling tape
thickness	0,6 mm
Metallic screen	
material	copper wires
cross-section	3 x 14 mm ²
Longitudinal water seal	
material	swelling tape
thickness	0,6 mm
Inner sheath	
material	PE
thickness	3,0 mm
Assembling	
material 1	polymeric profiles
material 2	fibre optical cable
material 3	grease
Cable core binder	
material	polymeric tape
thickness	0,2 mm
Bedding	
material	Bitumen impregnated tape
thickness	0,5 mm
Armour	
material 1	Galvanized steel wires
material 2	Bitumen
wire diameter	4,0 mm
Armour	
material 1	Polypropylene yarns
material 2	Bitumen
thickness	4,0 mm
Complete cable	
diameter	≈ 120 mm
weight	≈ 22 kg / m


FXCTV 3x500mm²
FXCTV 3x240mm²
FXCTV 3x95mm²



Tender Elsam
Our ref 05-1059
Page 14 of 14
Rev. 050929-4
2005-09-29

Burbo Offshore Windfarm
ABB Power Technologies AB High Voltage Cables

14. CABLE DESIGN FXCTV 3x95mm²



Designation
Rated voltage
Impulse level

FXCTV 3 x 95 mm²
20/34 kV U_{max} 36kV
170 kV

Conductor
type
material
cross-section

round, solid
copper
3 x 95 mm²

Conductor screen
thickness

0,8 mm

Insulation
type
material
thickness
diameter

dry cured, triple extruded
XLPE
8,0 mm
31 mm

Insulation screen
thickness

1,0 mm

Longitudinal water seal 1
material
thickness

conductive swelling tape
0,6 mm

Metallic screen
material
cross-section

copper wires mm
3 x 12 mm²

Longitudinal water seal 2
material
thickness

conductive swelling tape
0,6 mm

Inner sheath
material
thickness

PE
3,0 mm

Fillers
material
material
material

polymeric profiles
grease
fiber optic cable

Cable core binder
material
thickness

nylon
0,15 mm

Bedding
material

bitumen impregnated tape

Armour
type
material
thickness

wires, single layer
galv. steel wires
4 mm


Outer cover
material
thickness

polypropylene yarn
4 mm


Complete cable
diameter
weight

≈ 106 mm
≈ 16 kg / m

- Sketch of onshore jointing chamber. (CIF)
This is based on the assumption that the jointing chamber is an open design with only a concrete wall where the hang-off is fitted.



Where the armoured submarine cable enters the CIF, there shall be a concrete wall with open slots for the cable to attach the hang-off. These hang off devices will be of the same type as those being installed on the wind turbines. Splicing will be done in an open dug jointbay in a temporary jointing facility. After splicing the splices shall be buried in cable sand and the following layers backfilled and compacted.



Standby rate. Example.

The master time schedule states at what date we should have access to the different WT:s. When our personell are on site, and these dates are not met by another contractor such as foundation contractor, WT contractor or Cable laying contractor, the standby rate would be applicable, unless we are given access to other WT:s where we could continue with our work.

Example:

WT installation on foundations are delayed outside the time schedule for any technical reasons. This would be situation where the standby rate would be applicable.

All situations with standby time would have to be considered as separate items. We will ofcourse try our best to work together with all contractors to minimize standby time, for instance work in parallel with other contractors on WT:s whenever possible technically and concidering safety for personnel. Standby time would only be applicable for delays compared to the master time schedule. If we would work faster then our given time in the schedule, standby time would not be applicable for the time to the next planned operation. Our offer is based on that we can work in one continous operation.

Inspection and Test Plan

OBJECT: FXCTV 3x500/17 36 kV

Voltages and Cable Dimensions	
U = 34	kV Rated voltage
U _m = 36	kV Highest voltage for equipment (between conductors)
U ₀ = 18	kV Value of U ₀ for determination of test voltages
d = 26,2	mm Nominal diameter of conductor
t _i = 8,0	mm Nominal thickness of insulation
t _n = 2,0	mm Nominal thickness of cable oversheath
d _n = 4,0	mm Nominal diameter armour wires
D = 140	mm Nominal diameter of cable
C _n = 0,33	µF/km Nominal capacitance of cable core
R _c = 0,0366	ohm/km Conductor resistance DC 20 °C
R _s = 1,2	ohm/km Screen/sheath resistance DC 20 °C

Contents	page
Routine Test	1
Sample Test	2
Commissioning test	3
Fiber optical tests	4

No.	Name of item	Specifying documents ; Clause	Requirements	Code
	Characteristics, method or type of inspection			1, 2, 3

1. Routine test

Routine test shall be carried out on each manufactured length of cable

1.1	Measurement of electrical resistance of conductor	IEC 60502-2 16.2	20°C R _{DC} ≤ 0,0366 ohm/km	A-C
1.2	Measurement of electrical resistance of screen	IEC 60502-2 16.2	20°C R _{DC} ≤ 1,2 ohm/km	A-C
1.3	* Partial Discharge Test	IEC 60502-2 16.3	Test voltage raised to 36 kV held 10 s. ≤ 10 pC at U = 31 kV	A-C
1.4	Voltage Test	IEC 60502-2 16.4	5 minutes at U = 63 kV	A-C
1.5	Test on fiber optical cable	Please see page 4 in this document		

Code 1. Place of inspection

A at manufacturer (ABB company)
M at manufacturer outside ABB
S at a subcontractor of the manufacturer
E at erection site
X other, specified under "Remarks"

Code 2. Inspector

B customer/owner representative, mandatory hold point
C customer/owner representative
N representative of responsible ABB company
D representative of the manufacturers design function
P repr. of the manufact. quality function, mandatory hold point
Q representative of the manufacturers quality function
Y other, specified under "Remarks"
- witnessing not specified

Code 3. Distribution of report

C customer/owner and manufacturers quality function
N responsible ABB company and the manufacturers quality function
D the manufacturers design and quality functions
Q the manufacturers quality function
J journal is kept, no reporting for each delivery order
Z other, specified under "Remarks"
- reporting not specified

Remarks, notes

In order to avoid inaccuracy (due to temperature variations) all resistance measurement will be performed prior to assembling

* 1.3 is for information only. A PD-test will be performed on samples taken from beginning and end from each extrusion serie (Referring to Electra 189 2.2.2)

Rev. ind.	Specification of revision	Approved	Date
Responsible department		(Customer, Plant, Order, etc.)	
Technical Department		Seascope Energy UK (BURBO)	
Prepared by		Title	
TK Flemming Krogh		ITP xxxxx	
Approved by		Language	
TK Kenneth Johannesson		E	
Take over departments		No of sh.	
PVT, TM, Q, CC		4	
Manufacturer		Document No.	
ABB Power Technologies High Voltage Cables		Draft	
		Date	Sheet
		2005-10-04	1

Inspection and Test Plan

OBJECT: FXCTV 3x500/17 36 kV

Voltages and Cable Dimensions

U =	34	kV Rated voltage
U _m =	36	kV Highest voltage for equipment (between conductors)
U ₀ =	18	kV Value of U ₀ for determination of test voltages
d =	26,2	mm Nominal diameter of conductor
t _n =	8,0	mm Nominal thickness of insulation
t _i =	2,0	mm Nominal thickness of inner PE-sheath
d _n =	4,0	mm Nominal diameter of armour wires
D =	140	mm Nominal diameter of cable
C _n =	0,33	µF/km Nominal capacitance of cable core
R _c =	0,0366	ohm/km Conductor resistance DC 20 °C
R _s =	1,2	ohm/km Screen/sheath resistance DC 20 °C

Contents	page
Routine Test	1
Sample Test	2
Commissioning test	3
Fiber optical tests	4

No.	Name of item	Specifying documents : Clause	Requirements	Code
	Characteristics, method or type of inspection			1, 2, 3
2.	Sample test			
	The sample tests 2.1- 2.4 will be performed on samples taken from beginning and end from each extrusion serie			
	The sample test 2.5 will be performed on samples taken from beginning and end from each completed cable length			
2.1	Conductor examination	IEC 60502-2 17.4	≥ 53 wires	A-C
2.2	Measurement of thickness of insulation and non-metallic sheath			
2.2.1	Measurement of insulation	IEC 60502-2 17.5.2	t _{min} ≥ 7,1 mm	A-C
2.2.2	Measurement of cable oversheath	IEC 60502-2 17.5.3	t _{max} -t _{min} /t _{max} < 0,15 mm t _{min} ≥ 1,40 mm	A-C
2.3	Partial Discharge Test	IEC 60502-2 16.3	Test voltage raised to 36 kV held 10 s. ≤ 10 pC at U = 31 kV	A-C
2.4	Hot Set Test for XLPE-Insulation	IEC 60502-2 17.5.10	IEC60502-2 Table 22 XLPE	A-C
2.5	Measurement of diameter of armour wires	IEC 60502-2 17.7.7	d _{min} ≥ 3,8 mm	A-C

Code 1. Place of inspection		Code 2. Inspector		Code 3. Distribution of report	
A at manufacturer (ABB company) M at manufacturer outside ABB S at a subcontractor of the manufacturer E at erection site X other, specified under "Remarks"		B customer/owner representative, mandatory hold point C customer/owner representative N representative of responsible ABB company D representative of the manufacturers design function P repr. of the manufact. quality function, mandatory hold point Q representative of the manufacturers quality function Y other, specified under "Remarks" - witnessing not specified		C customer/owner and manufacturers quality function N responsible ABB company and the manufacturers quality function D the manufacturers design and quality functions Q the manufacturers quality function J journal is kept, no reporting for each delivery order Z other, specified under "Remarks" - reporting not specified	
Remarks, notes					
Rev. ind.		Specification of revision		Approved Date	
Responsible department				(Customer, Plant, Order, etc.)	
Technical Department				Seascope Energy UK (BURBO)	
Prepared by				Title	
TK Flemming Krogh				ITP xxxxx	
Approved by				Language	
TK Kenneth Johannesson				E	
Take over departments				No of sh.	
PVT, TM, Q, CC				4	
Manufacturer				Document No.	
ABB Power Technologies High Voltage Cables				Draft	
				Date	
				2005-10-04	
				Sheet	
				2	

Inspection and Test Plan

OBJECT: FXCTV 3x500/17 36 kV

Voltages and Cable Dimensions	
U = 34	kV Rated voltage
U _m = 36	kV Highest voltage for equipment (between conductors)
U ₀ = 18	kV Value of U ₀ for determination of test voltages
d = 26,2	mm Nominal diameter of conductor
t _n = 8,0	mm Nominal thickness of insulation
t _i = 2,0	mm Nominal thickness of inner PE-sheath
d _n = 4,0	mm Nominal diameter of armour wires
D = 140	mm Nominal diameter of cable
C _n = 0,33	µF/km Nominal capacitance of cable core
R _c = 0,0366	ohm/km Conductor resistance DC 20 °C
R _s = 1,2	ohm/km Screen/sheath resistance DC 20 °C

Contents	page
Routine Test	1
Sample Test	2
Commissioning test	3
Fiber optical tests	4

No.	Name of item.	Specifying documents ; Clause	Requirements	Code
	Characteristics, method or type of inspection			1, 2, 3

3. Electrical tests after installation

After installation test shall be carried out on installed cable

3.1	AC or DC test	IEC 60502-2 20)	(to be decided)	ECC
3.2	Test on fiber optical cable	Please see page 4 in this document		ECC

Code 1. Place of inspection

A at manufacturer (ABB company)
M at manufacturer outside ABB
S at a subcontractor of the manufacturer
E at erection site
X other, specified under "Remarks"

Code 2. Inspector

B customer/owner representative, mandatory hold point
C customer/owner representative
N representative of responsible ABB company
D representative of the manufacturers design function
P rep. of the manufact. quality function, mandatory hold point
Q representative of the manufacturers quality function
Y other, specified under "Remarks"
- witnessing not specified

Code 3. Distribution of report

C customer/owner and manufacturers quality function
N responsible ABB company and the manufacturers quality function
D the manufacturers design and quality functions
Q the manufacturers quality function
J Journal is kept, no reporting for each delivery order
Z other, specified under "Remarks"
- reporting not specified

Remarks, notes

Rev. ind.	Specification of revision	Approved	Date
-----------	---------------------------	----------	------

Responsible department

Technical Department

Prepared by

TK Flemming Krogh

Approved by

TK Kenneth Johannesson

Take over departments

PVT, TM, Q, CC

Manufacturer

ABB Power Technologies High Voltage Cables

(Customer, Plant, Order, etc.)

Seascope Energy UK (BURBO)

Title

ITP xxxxx

FXCTV 3x500/17 36 kV

Document No.

Draft

Date

2005-10-04

Language

E

No of sh.

4

Sheet

3

Inspection and Test Plan

OBJECT: FXCTV 3x500/17 36 kV

Voltages and Cable Dimensions

U =	34	kV Rated voltage
U _m =	36	kV Highest voltage for equipment (between conductors)
U ₀ =	18	kV Value of U ₀ for determination of test voltages
d =	26,2	mm Nominal diameter of conductor
t _n =	8,0	mm Nominal thickness of insulation
t _n =	2,0	mm Nominal thickness of cable oversheath
D =	140	mm Nominal diameter of cable
C _n =	0,33	µF/km Nominal capacitance of cable core
R _c =	0,0366	ohm/km Conductor resistance DC 20 °C
R _s =	1,2	ohm/km Screen/sheath resistance DC 20 °C

Contents	page
Routine Test	1
Sample Test	2
Commissioning test	3
Fiber optical tests	4

No.	Name of item.	Specifying documents ; Clause	Requirements	Code
	Characteristics, method or type of inspection			1, 2, 3
	Tests on fiber optical cable	IEC 60793-1-C1C		
	<i>The following tests will be performed on completed cable</i>			
3.1	OTDR Test on all fibres (Measurements must be performed from both ends)			
	Attenuation at 1310 nm.		≤ 0.35 dB/km	M-C
	Attenuation at 1550 nm.		≤ 0.25 dB/km	M-C
	Attenuation at 1625 nm.		≤ 0.25 dB/km	M-C
	Minimum number of approved fibres		16 pcs	M-C
	<i>The following tests will be performed as a part of the routine test.</i>			
	The test will be repeated after loading			
3.2	OTDR Test on all fibres (Measurements must be performed from both ends)			
	Attenuation at 1310 nm.		≤ 0.35 dB/km	A-C
	Attenuation at 1550 nm.		≤ 0.25 dB/km	A-C
	Attenuation at 1625 nm.		≤ 0.25 dB/km	A-C
	Minimum number of approved fibres		12 pcs	A-C
	<i>The following tests will be performed as a part of the commissioning test.</i>			
3.2	OTDR Test on all fibres (Measurements must be performed from both ends)			
	Attenuation at 1310 nm.		≤ 0.35 dB/km	E-C
	Attenuation at 1550 nm.		≤ 0.25 dB/km	E-C
	Attenuation at 1625 nm.		≤ 0.25 dB/km	E-C
	Minimum number of approved fibres		12 pcs	E-C

Code 1. Place of inspection

A at manufacturer (ABB company)
M at manufacturer outside ABB
S at a subcontractor of the manufacturer
E at erection site
X other, specified under "Remarks"

Code 2. Inspector

B customer/owner representative, mandatory hold point
C customer/owner representative
N representative of responsible ABB company
D representative of the manufacturers design function
P repr. of the manufact. quality function, mandatory hold point
Q representative of the manufacturers quality function
Y other, specified under "Remarks"
- witnessing not specified

Code 3. Distribution of report

C customer/owner and manufacturers quality function
N responsible ABB company and the manufacturers quality function
D the manufacturers design and quality functions
Q the manufacturers quality function
J journal is kept, no reporting for each delivery order
Z other, specified under "Remarks"
- reporting not specified

Remarks, notes

Rev. Ind.	Specification of revision	Approved	Date
Responsible department		(Customer, Plant, Order, etc.)	
Technical Department		Seascope Energy UK (BURBO)	
Prepared by		Title	
TK Flemming Krogh		ITP xxxxx	
Approved by		Language	
TK Kenneth Johannesson		E	
Take over departments		No of sh.	
PVT, TM, Q, CC		4	
Manufacturer		Document No.	
ABB Power Technologies High Voltage Cables		Draft	
		Date	
		2005-10-04	
		Sheet	
		4	

Inspection and Test Plan

OBJECT: FXCTV 3x95/12 36 kV

Voltages and Cable Dimensions		Contents	page
U = 34	kV Rated voltage	Routine Test	1
U _m = 36	kV Highest voltage for equipment (between conductors)	Sample Test	2
U ₀ = 18	kV Value of U ₀ for determination of test voltages	Commissioning test	3
d = 11	mm Nominal diameter of conductor	Fiber optical tests	4
t _n = 8,0	mm Nominal thickness of insulation		
t _n = 3	mm Nominal thickness of cable oversheath		
d _n = 4,0	mm Nominal diameter armour wires		
D = 106	mm Nominal diameter of cable		
C _n = 0,17	µF/km Nominal capacitance of cable core		
R _c = 0,193	ohm/km Conductor resistance DC 20 °C		
R _s = 1,5	ohm/km Screen/sheath resistance DC 20 °C		

No.	Name of item	Specifying documents ; Clause	Requirements	Code
	Characteristics, method or type of inspection			1, 2, 3

1. Routine test

Routine test shall be carried out on each manufactured length of cable

1.1	Measurement of electrical resistance of conductor	IEC 60502-2 16.2	20°C R _{DC} ≤ 0,193 ohm/km	A-C
1.2	Measurement of electrical resistance of screen	IEC 60502-2 16.2	20°C R _{DC} ≤ 1,5 ohm/km	A-C
1.3	Partial Discharge Test	IEC 60502-2 16.3	Test voltage raised to 36 kV held 10 s. ≤ 10 pC at U = 31 kV	A-C
1.4	Voltage Test	IEC 60502-2 16.4	5 minutes at U = 63 kV	A-C
1.5	Test on fiber optical cable	Please see page 4 in this document		

Code 1. Place of inspection

A at manufacturer (ABB company)
M at manufacturer outside ABB
S at a subcontractor of the manufacturer
E at erection site
X other, specified under "Remarks"

Code 2. Inspector

B customer/owner representative, mandatory hold point
C customer/owner representative
N representative of responsible ABB company
D representative of the manufacturers design function
P repr. of the manufact. quality function, mandatory hold point
Q representative of the manufacturers quality function
Y other, specified under "Remarks"
- witnessing not specified

Code 3. Distribution of report

C customer/owner and manufacturers quality function
N responsible ABB company and the manufacturers quality function
D the manufacturers design and quality functions
Q the manufacturers quality function
J journal is kept, no reporting for each delivery order
Z other, specified under "Remarks"
- reporting not specified

Remarks, notes

In order to avoid inaccuracy (due to temperature variations) all resistance measurement will be performed prior to assembling

Rev. ind.	Specification of revision	Approved	Date
Responsible department		(Customer, Plant, Order, etc.)	
Technical Department		Seascope Energy UK (BURBO)	
Prepared by			
TK Flemming Krogh			
Approved by		Title	
TK Kenneth Johannesson		ITP xxxxx	
Take over departments		Language	
PVT, TM, Q, CC		E	
Manufacturer		No of sh.	
ABB Power Technologies High Voltage Cables		4	
		Document No.	
		Draft	
		Date	
		2005-10-04	
		Sheet	
		1	

Inspection and Test Plan

OBJECT: FXCTV 3x95/12 36 kV

Voltages and Cable Dimensions

U =	34	kV Rated voltage
U _m =	36	kV Highest voltage for equipment (between conductors)
U ₀ =	18	kV Value of U ₀ for determination of test voltages
d =	11	mm Nominal diameter of conductor
t _n =	8,0	mm Nominal thickness of insulation
t _n =	3	mm Nominal thickness of inner PE-sheath
d _n =	4,0	mm Nominal diameter of armour wires
D =	106	mm Nominal diameter of cable
C _n =	0,17	µF/km Nominal capacitance of cable core
R _c =	0,193	ohm/km Conductor resistance DC 20 °C
R _s =	1,5	ohm/km Screen/sheath resistance DC 20 °C

Contents

	page
Routine Test	1
Sample Test	2
Commissioning test	3
Fiber optical tests	4

No.	Name of item. Characteristics, method or type of inspection	Specifying documents ; Clause	Requirements	Code 1, 2, 3
-----	--	-------------------------------	--------------	-----------------

2. Sample test

The sample tests 2.1- 2.4 will be performed on samples taken from beginning and end from each extrusion serie
The sample test 2.5 will be performed on a sample taken from first and last completed cable length.

2.1	Conductor examination	IEC 60502-2 17.4	Solid conductor	A-C
2.2	Measurement of thickness of insulation and non-metallic sheath			
2.2.1	Measurement of insulation	IEC 60502-2 17.5.2	$t_{min} \geq 7,1 \text{ mm}$	A-C
2.2.2	Measurement of cable oversheath	IEC 60502-2 17.5.3	$t_{max}-t_{min}/t_{max} < 0,15 \text{ mm}$ $t_{min} \geq 2,20 \text{ mm}$	A-C
2.3	Hot Set Test for XLPE-Insulation	IEC 60502-2 17.5.10	IEC60502-2 Table 22 XLPE	A-C
2.4	Measurement of diameter of armour wires	IEC 60502-2 17.7.7	$d_{min} \geq 3,8 \text{ mm}$	A-C

Code 1. Place of inspection

A at manufacturer (ABB company)
M at manufacturer outside ABB
S at a subcontractor of the manufacturer
E at erection site
X other, specified under "Remarks"

Code 2. Inspector

B customer/owner representative, mandatory hold point
C customer/owner representative
N representative of responsible ABB company
D representative of the manufacturers design function
P recr. of the manufact. quality function, mandatory hold point
Q representative of the manufacturers quality function
Y other, specified under "Remarks"
- witnessing not specified

Code 3. Distribution of report

C customer/owner and manufacturers quality function
N responsible ABB company and the manufacturers quality function
D the manufacturers design and quality functions
Q the manufacturers quality function
J journal is kept, no reporting for each delivery order
Z other, specified under "Remarks"
- reporting not specified

Remarks, notes

Rev. ind.	Specification of revision	Approved	Date
Responsible department		(Customer, Plant, Order, etc.)	
Technical Department		Seascope Energy UK (BURBO)	
Prepared by	TK Flemming Krogh	Title	ITP xxxxx
Approved by	TK Kenneth Johannesson	Language	E
Take over departments	PVT, TM, Q, CC	No of sh.	4
Manufacturer	ABB Power Technologies High Voltage Cables	Document No.	Draft
		Date	2005-10-04
		Sheet	2

Inspection and Test Plan

OBJECT: FXCTV 3x95/12 36 kV

Voltages and Cable Dimensions

U =	34	kV Rated voltage
U _m =	36	kV Highest voltage for equipment (between conductors)
U ₀ =	18	kV Value of U ₀ for determination of test voltages
d =	26,2	mm Nominal diameter of conductor
t _n =	8,0	mm Nominal thickness of insulation
t _{in} =	2,0	mm Nominal thickness of inner PE-sheath
d _n =	4,0	mm Nominal diameter of armour wires
D =	140	mm Nominal diameter of cable
C _n =	0,33	μF/km Nominal capacitance of cable core
R _c =	0,0366	ohm/km Conductor resistance DC 20 °C
R _s =	1,2	ohm/km Screen/sheath resistance DC 20 °C

Contents	page
Routine Test	1
Sample Test	2
Commissioning test	3
Fiber optical tests	4

No.	Name of item	Specifying documents : Clause	Requirements	Code
	Characteristics, method or type of inspection			1, 2, 3
3.	Electrical tests after installation			
	After installation test shall be carried out on installed cable			
3.1	AC or DC test	IEC 60502-2 20)	(to be decided)	ECC
3.2	Test on fiber optical cable	Please see page 4 in this document		ECC

Code 1. Place of inspection

A at manufacturer (ABB company)
M at manufacturer outside ABB
S at a subcontractor of the manufacturer
E at erection site
X other, specified under "Remarks"

Code 2. Inspector

B customer/owner representative, mandatory hold point
C customer/owner representative
N representative of responsible ABB company
D representative of the manufacturers design function
P repr. of the manufact. quality function, mandatory hold point
Q representative of the manufacturers quality function
Y other, specified under "Remarks"
- witnessing not specified

Code 3. Distribution of report

C customer/owner and manufacturers quality function
N responsible ABB company and the manufacturers quality function
D the manufacturers design and quality functions
Q the manufacturers quality function
J Journal is kept, no reporting for each delivery order
Z other, specified under "Remarks"
- reporting not specified

Remarks, notes

Rev. ind.	Specification of revision	Approved	Date
Responsible department		(Customer, Plant, Order, etc.)	
Technical Department		Seascope Energy UK (BURBO)	
Prepared by			
TK Flemming Krogh			
Approved by		Title	Language
TK Kenneth Johannesson		ITP xxxxx	E
Take over departments			No of sh.
PVT, TM, Q, CC		FXCTV 3x95/12 36 kV	4
Manufacturer		Document No.	Sheet
ABB Power Technologies High Voltage Cables		Draft	3
		Date	2005-10-04

Inspection and Test Plan

OBJECT: FXCTV 3x95/12 36 kV

Voltages and Cable Dimensions	
U = 34	kV Rated voltage
U _m = 36	kV Highest voltage for equipment (between conductors)
U ₀ = 18	kV Value of U ₀ for determination of test voltages
d = 11	mm Nominal diameter of conductor
t _n = 8,0	mm Nominal thickness of insulation
t ₀ = 3	mm Nominal thickness of cable oversheath
D = 106	mm Nominal diameter of cable
C ₀ = 0,17	μF/km Nominal capacitance of cable core
R _c = 0,193	ohm/km Conductor resistance DC 20 °C
R _s = 1,5	ohm/km Screen/sheath resistance DC 20 °C

Contents	page
Routine Test	1
Sample Test	2
Commissioning test	3
Fiber optical tests	4

No.	Name of item	Specifying documents / Clause	Requirements	Code
	Characteristics, method or type of inspection			1, 2, 3

Tests on fiber optical cable IEC 60793-1-C1C

The following tests will be performed on completed cable

3.1	OTDR Test on all fibres (Measurements must be performed from both ends)		
	Attenuation at 1310 nm.	≤ 0.35 dB/km	M-C
	Attenuation at 1550 nm.	≤ 0.25 dB/km	M-C
	Attenuation at 1625 nm.	≤ 0.25 dB/km	M-C
	Minimum number of approved fibres	16 pcs	M-C

The following tests will be performed as a part of the routine test.

The test will be repeated after loading

3.2	OTDR Test on all fibres (Measurements must be performed from both ends)		
	Attenuation at 1310 nm.	≤ 0.35 dB/km	A-C
	Attenuation at 1550 nm.	≤ 0.25 dB/km	A-C
	Attenuation at 1625 nm.	≤ 0.25 dB/km	A-C
	Minimum number of approved fibres	12 pcs	A-C

The following tests will be performed as a part of the commissioning test.

3.2	OTDR Test on all fibres (Measurements must be performed from both ends)		
	Attenuation at 1310 nm.	≤ 0.35 dB/km	E-C
	Attenuation at 1550 nm.	≤ 0.25 dB/km	E-C
	Attenuation at 1625 nm.	≤ 0.25 dB/km	E-C
	Minimum number of approved fibres	12 pcs	E-C

Code 1. Place of inspection	Code 2. Inspector	Code 3. Distribution of report
A at manufacturer (ABB company)	B customer/owner representative, mandatory hold point	C customer/owner and manufacturers quality function
M at manufacturer outside ABB	C customer/owner representative	N responsible ABB company and the manufacturers quality function
S at a subcontractor of the manufacturer	N representative of responsible ABB company	D the manufacturers design and quality functions
E at erection site	D representative of the manufacturers design function	Q the manufacturers quality function
X other, specified under "Remarks"	P repr. of the manufact. quality function, mandatory hold point	J journal is kept, no reporting for each delivery order
	Q representative of the manufacturers quality function	Z other, specified under "Remarks"
	Y other, specified under "Remarks"	- reporting not specified
	- witnessing not specified	

Remarks, notes

Rev. ind.	Specification of revision	Approved	Date	
Responsible department		(Customer, Plant, Order, etc.)		
Technical Department		Seascope Energy UK (BURBO)		
Prepared by		Title		
TK Flemming Krogh				
Approved by		Language		
TK Kenneth Johannesson				
Take over departments		No of sh.		
PVT, TM, Q, CC				
Manufacturer		Sheet		
ABB Power Technologies High Voltage Cables		4		
Document No.		Date		
Draft		2005-10-04		