

Medium Voltage Cable Accessories

A Theoretical & Practical Appraisal

Dr. Derek Goulsbra
CEng. MIET

The Nexans logo features a stylized orange 'N' followed by the word 'exans' in a grey sans-serif font.

Medium Voltage Cable Accessories

A Theoretical & Practical Appraisal

Dr. Derek Goulsbra

CEng. MIET



Published by Nexans Power Accessories (UK) Ltd

Unit 2
Aire & Calder Industrial Park
Lock Lane
Castleford
West Yorkshire
United Kingdom WF10 2JA

www.nexans.co.uk

+44 (0) 1977 669966
sales@nexansdirect.com

First published 2012
Text © Derek Goulsbra CEng. MIET
Images © Nexans Power Accessories (UK) Ltd

ISBN: 978-0-9573785-0-6

The moral right of Derek Goulsbra to be identified as the author of this work has been asserted.

All rights reserved. No part of this book may be reproduced or transferred in any form or by any means, graphic, electronic, or mechanical, including photocopying, recording, taping, or by any information storage retrieval system, without the written permission of the author.

Although the author and publisher have made every effort to ensure that the information in this book was correct at press time, the author and publisher do not assume and hereby disclaim any liability to any party for any loss, damage, or disruption caused by errors or omissions, whether such errors or omissions result from negligence, accident, or any other cause. The contents of this book do not constitute or replace any manufacturers installation procedures. It is the responsibility of installers to ensure that they are adequately trained in the installation of medium voltage accessories. Nexans Power Accessories (UK) Ltd and the author will not be held responsible for incorrect installation practises that deviate from manufacturers installation procedures issued with accessories.

Foreword

iii

This book is a follow up to an earlier edition entitled "Some thoughts on MV cable accessories". Greater emphasis is placed on modes of failure and ways to overcome potential problems encountered in the field. It is the aim of the book to provide as much information as possible to engineers and jointers who are responsible for specifying and installing these products. It is hoped that by following the information presented, the reliability of accessories will be improved thus saving considerably on the cost of failures due to loss of supply, labour and equipment replacement.

Cable accessories account for the least capital expenditure in the distribution network when compared with switchgear, transformers and cables, but can prove to be the weakest part of it because they have to be assembled on site. This book will describe in detail the workings of accessories and show why common faults can occur and the steps to be taken to prevent problems.

Some of the mathematics and associated assumptions relating to voltage distribution in this work are simplified and two-dimensional. In reality we are looking at complex three-dimensional models, but it is felt that it is unnecessary to proceed down this path in order to explain in broad terms how certain phenomena occur. The author makes no apology for this, but begs the reader understands the purpose of the work.

Nexans Power Accessories (UK) Ltd

iv Acknowledgements

I am indebted to the help and encouragement given by Gary Halton, Mick Dawn, Emma Hutton and Jon Rhodes of Nexans Power Accessories (UK) Ltd. The following companies have been most helpful in providing information and illustrations and their cooperation is much appreciated.

- CMP Products – www.cmp-products.co.uk
- Ellis Patents Ltd – www.ellispatents.co.uk
- W T Henley Limited – www.wt-henley.com
- Nexans Power Accessories (UK) Ltd – www.nexans.co.uk

Contents

v

Chapter 1	An introduction	1
Chapter 2	Electrical breakdown of air and solid dielectrics	3
	2.1. Electrical breakdown of air	
	2.2. Electrical breakdown of solid insulating materials	
	2.3. Effect of air/solid combinations on voltage distribution	
	2.3.1. Voltage distribution between infinite parallel plates	
	2.3.2. Voltage distribution between concentric cylinders	
	2.3.3. Voltage distribution between concentric cylinders with two dielectrics	
	2.3.4. Maximum electric stress in a cylindrical dielectric	
Chapter 3	Some practical examples of mixed dielectrics in accessories	19
	3.1. Cable breakout area of paper belted cable	
	3.2. Adjacent unscreened cores	
	3.3. The end of an earth screen on polymeric cable	
	3.4. Area surrounding a connector in a joint	

Chapter 4	Some notes on cable preparation	23
	4.1. Tools for removing outer sheath and insulation	
	4.2. Removing a bonded screen	
	4.3. Removing easy peel screen	
	4.3.1. Method 1 – using basic tools	
	4.3.2. Method 2 – using sophisticated tooling	
	4.4. Graphite coated conductive tape wrapped cores	
Chapter 5	Treating the screen cut on polymeric cables	31
	5.1. The problem area	
	5.2. Some techniques for eliminating potential voids	
	5.2.1. Conductive paint	
	5.2.2. Void filling stress relieving tape	
	5.2.3. Pliable stress control	
	5.3. Pros and Cons	
Chapter 6	Stress control on paper belted cables	35
	6.1. Initial preparation of paper belted cable	
	6.2. Cable breakout area of unscreened paper cable	
	6.3. Screening the cable cores	
Chapter 7	Stress control in polymeric cable accessories	41
	7.1. Stresses within a cable	
	7.2. Stress control at screen cut	
	7.2.1. Swamping	
	7.2.2. Geometric stress control	
	7.2.3. Electrical stress control	
	7.3. Stress control in joints	
	7.3.1. Stress relieving tape around the connector	
	7.3.2. The Faraday Cage	
Chapter 8	Terminations 1 – A practical appraisal	49
	8.1. The function of a termination	
	8.2. Management of air	

	8.2.1. Paper belted terminations	
	8.2.2. Screened cable terminations	
	8.2.3. Screened cable terminations – some examples	
	8.3. Connection to equipment bushings	
	8.3.1. Heat shrink mouldings	
	8.3.2. Push on mouldings	
	8.4. Issues with bushing connection insulating systems	
	8.5. Outdoor terminations	
Chapter 9	Terminations 2 – Separable connectors	63
	9.1. Introduction	
	9.2. A screened separable connector	
	9.3. Bushings	
	9.4. Cable reducers	
	9.5. Connecting to a bushing	
	9.6. Connecting more than one cable per phase	
Chapter 10	Terminations 3 – Earthing	71
	10.1. Introduction	
	10.2. Outdoor terminations	
	10.2.1. Single core cable with copper wires or copper tape screen	
	10.2.2. Single core polymeric cable with aluminium armour	
	10.2.3. Three core polymeric cable with steel wire armour	
	10.2.4. Three core paper cable with corrugated aluminium sheath	
	10.2.5. Paper cable with lead sheath and steel wire armours	
	10.2.6. Three core paper cable with steel tape armour	
	10.3. Indoor terminations	
	10.3.1. Single core unarmoured polymeric cable	
	10.3.2. Single core cable with tape screen and armours	
	10.3.3. Three core paper cable with corrugated aluminium sheath	
	10.3.4. Three core cable with steel wire armours	

10.4. Compression glands

10.4.1. Ingress protection – IP ratings

10.4.2. Gland seals

10.4.3. Cable support

10.4.4. Cable earthing

Chapter 11 Terminations 4 – The effect of moisture 87

11.1. Introduction

11.2. Formation of a conductive layer on terminations

11.2.1. Clean moisture

11.2.2. Industrially polluted moisture

11.2.3. Coastal moisture

11.2.4. Condensation

11.3. Effect of a conductive layer

11.4. The possible effects of discharges on polluted terminations

11.4.1. Surface degradation of the outer material of a termination

11.4.1.1. Surface tracking

11.4.1.2. Anaerobic tracking

11.4.1.3. Surface erosion

11.4.1.4. Surface flashover

11.5. Sealing of terminations

11.6. Reducing the effects of surface discharge

Chapter 12 Joints – An overview 95

12.1. Introduction

12.2. Connecting the conductors

12.2.1. Crimped connectors

12.2.2. Mechanical connectors

12.3. The elimination of air from critical areas

12.3.1. Stress relieving tape

12.3.2. Faraday Cage

	12.4. Stress control	
	12.4.1. Geometric type – a) push on	
	12.4.2. Geometric type – b) cold shrink	
	12.4.3. High permittivity	
	12.5. Thickness of insulation	
	12.6. Sealing the joint	
	12.6.1. The one piece joint	
	12.6.2. The multi layered joint	
	12.7. Earthing	
	12.7.1. Single core	
	12.7.2. Three core joint earth	
	12.8. Mechanical strength	
	12.9. Hybrid joints	
	12.9.1. Moulded Faraday Cage over connector	
	12.9.2. Shrink tubes and resin combination	
Chapter 13	Earthing of single core cables	109
	13.1. Induced voltages and currents in single core cables	
	13.1.1. Induced voltage	
	13.1.2. Induced current	
	13.2. Some practical situations	
	13.2.1. Short cable length	
	13.2.2. Medium cable length	
	13.2.3. Long cable runs	
	13.3. Fault caused by circulating current	
	13.4. Conclusions	
Chapter 14	Type testing of accessories	115
	14.1. Introduction	
	14.2. Some qualification tests for accessories	
	14.2.1. DC withstand	
	14.2.2. AC dry withstand	
	14.2.3. AC wet withstand – outdoor terminations only	

	14.2.4. Partial discharge	
	14.2.5. Impact test – joints only	
	14.2.6. Thermal cycling	
	14.2.7. Impulse voltage withstand	
	14.2.8. Humidity – indoor terminations only	
	14.2.9. Salt fog test – outdoor terminations only	
	14.2.10. Immersion test – outdoor terminations only	
	14.2.11. Thermal short circuit	
	14.2.12. Dynamic short circuit	
	14.2.13. Inspection	
	14.3. Test voltage levels	
	14.4. Testing terminations to HD 629/BS 7888	
	14.5. Testing joints to HD 629/BS 7888	
	14.6. Testing screened separable connectors	
	14.7. Limitations of type testing	
Chapter 15	Surge arresters	129
	15.1. Introduction	
	15.2. Metal Oxide Arrester	
	15.3. Typical surge arresters and connections	
Chapter 16	Testing of cable and equipment	133
Chapter 17	Cable supports	141
	17.1. Introduction	
	17.2. Cleats	
	17.2.1. Requirements	
	17.2.2. Cleat spacing	
	17.2.3. Cleat specifications	
	17.2.4. Trefoil cables with low short circuit levels	
	17.2.5. Trefoil cables with moderate short circuit levels	
	17.2.6. Trefoil cables with high short circuit levels	
	17.2.7. Triplex cables	
	17.3. Short circuit test with correctly installed cleats	

Chapter 18	Recent developments	147
	18.1. Terminations	
	18.1.1. Push on	
	18.1.2. Cold shrink	
	18.2 Joints	
	18.3. Separable connectors	
	18.3.1. Larger rated systems	
	18.3.2. Reduced size of products	
Chapter 19	A review	155
	19.1. Introduction	
	19.2. Dos and don'ts	
	19.3. The future	

This book is a detailed look at medium voltage cable accessories which will be of value to jointers and engineers alike. In order to understand the workings and failure modes of the accessories, a section on electrical breakdown of air and solids and a combination of the two is presented.

This is followed by a practical consideration of cable preparation using present day techniques and tools prior to installing the accessory.

Terminations, separable connectors, joints and associated components are examined in detail with explanations of the various technologies employed.

Finally, examples of failures are presented with explanations of how these could have been avoided.



THORNE &
DERRICK
INTERNATIONAL

Thorne & Derrick
+44 (0) 191 410 4292
www.powerandcables.com

ISBN 978-0-9573785-0-6



9 780957 378506 >