





LINK BOX TECHNICAL DATA SHEET

Drw. No. 04.10.11 Article No. 05811001/0

 Issued Date:
 4.08.2021

 Rev. Date:


 Rev.
 00

Туре	LB. U . E . 1.1		
- Description	One Phase Earthing Link Box for Single Cable		
- Designation	Underground		
- Bonding	Earthing N/A		
- Sheath Voltage Limiter			
- Phase No.	1		
Earth	1		
Drawing Number	04.10.11		
- Article No	05811001/0		
Electrical Characteristics			
- Rated Frequency	50/60 Hz		
- SVL Type (*)	N/A		
Protection Class	IP 68		
Material			
- Enclosure	Stainless Steel AISI304 (AISI316 optional)		
- Body Thickness (**)	2 mm		
- Cover Thickness	3 mm		
- Connection Links	10 μm Tinned Electrolytic Copper		
- Connection Links Dimension	40x10 mm (400 mm2)		
- Gasket	Silicone 2x48 mm Silicone gasket & EPR tape & Mastic Tape & Heat Shirinkable Tube		
- Cable Glands			
- Cable Glands Insulation			
- Insulation	Epoxy Support Insulator		
- Conductor Fixing	Conductor Flexconn - 95-400 mm2		
- Painting Process	Electro Static Polyester Powder Pain RAL 7032 Stainless Stee		
- Painting Code			
- Labeling Material			
- Protection Cover	PET-G		
AC Impulse Test			
- Phase-to-Phase	N/A kV		
- Phase-to-Earth	40 kV		
Voltage Withstand Test			
- AC	20 kV/1 min		
- DC	25 kV/5 min		
Short Circuit Test	70		
- Symmetrical	50 kA/1sec		
lateral Barra Arcina Trat/Occurred C	40		
Internal Power Arcing Test (Symmetrical)	40 kA/0.1 sec		


^{*} In case of mismatch in given values, technical drawing provided along with the Order Confirmation is valid. Ask for conformity if SVL is out of EMELEC's scope.

^{**} Body Thickness might differ related to technical drawing revision. For exact value, refer to technical drawing provided along with the Order Confirmation

Bonding Cable



Schematic Diagram



Enclosure Dimensions (*)

Width	400 mm	
Length	380 mm	
Heigth	289 mm	
Weigth	25 kg	
Filling Compund (C	ptional)	
Volume	15 lt (**)	

Scheme and dimensions are not to be mentioned as final drawing. For exact dimensions, refer to technical drawing provided along with the Order Confirmation
 Given are approximate values. Actual values might sligthly differ.